

RESOLUTION 21-79

A RESOLUTION OF THE CITY OF PANAMA CITY BEACH, FLORIDA, APPROVING AN EMERGENCY PURCHASE OF A REPLACEMENT PUMP FOR LIFT STATION 109 FROM JIM HOUSE & ASSOCIATES, INC. IN THE BASIC AMOUNT OF \$17,500.

WHEREAS, City Lift Station 109 is fitted with 2 pumps, for which the second and backup pump failed while the first pump was out for repair; and

WHEREAS, given the immediate threat to the health, safety and welfare of citizens caused by the total pump failure, staff solicited quotes from vendors to provide a replacement pump, and on January 29, 2021, the City Manager approved a purchase of an identical replacement pump; and

WHEREAS, the Council finds and determines that the simultaneous failure of both pumps at Lift Station 109 constituted an emergency which required immediate action to protect the health safety and welfare, for which the City's standard competitive bidding process would have created a delay contrary to the public health and the public interest; and

WHEREAS, the Council finds and determines that the solicitation of quotes was a necessary and appropriate substitution for the competitive bidding otherwise required.

NOW THEREFORE BE IT RESOLVED that the City Council hereby approves, and to the extent necessary ratifies, that certain Agreement between the City and Jim House & Associates Inc., relating to the emergency purchase of a replacement pump for Lift Station 109, in the basic amount of Seventeen Thousand, Five Hundred Dollars (\$17,500), on substantially the terms and conditions of the quote attached and presented to the Council today, draft dated January 29, 2021 with such changes, insertions or omissions as may be approved by the City Manager and whose execution shall be conclusive evidence of such approval.

[SIGNATURES ON FOLLOWING PAGE]

THIS RESOLUTION shall be effective immediately upon passage.

PASSED in regular session this 11th day February, 2021.

CITY OF PANAMA CITY BEACH

By: 
Mark Sheldon, Mayor

ATTEST:


Lynne Fasone, City Clerk

Jim House & Associates, Inc.
 1401 Georgia Road
 Irondale, AL 35210
 PO Box 101957 (35210)
 (205) 592-6302 (800) 292-6335
 Fax: (205) 951-0291



Since 1957

Quote

Gulf Coast Office
 24312 Highway 98
 Fairhope, AL 36532
 (251) 928-7867 (800) 919-7867
 Fax: (251) 928-7804

Date
1/29/2021

Quote #
14735

Name / Address
CITY OF PANAMA CITY BEACH 110 SOUTH ARNOLD ROAD PANAMA CITY BCH FL 32413

Ship To
CITY OF PANAMA CITY BEACH ATTN: KEITH SIMS 206 N. GULF BLVD PANAMA CITY BEACH, FL 32413

*Dear customer,
 As requested, we are pleased to provide a quotation for the following equipment:*

Qty	Manufacturer	Item Description
	FLYGT	LS 109 - Antiqua - 20HP Replacement Pump SUBMERSIBLE HARD-IRON N IMPELLER PUMP MODEL NP3153.095-463 (230/3/60, FLS, 20HP, FM EXPLOSION PROOF MOTOR), FREIGHT CURRENT DELIVERY IS STOCK

Only the items mentioned specifically herein are included. Additional equipment required for installation such as main electrical service, conduit and wire, discharge piping and/or valves, concrete, or any other necessary items are not included in our proposal and are to be provided by others. Pricing is subject to the attached terms and conditions. Service is available at the per diem rates shown in the attached terms and conditions. All pricing is firm for 30 days from the above date.

Sales Tax (0.0%)	\$0.00
Total:	\$17,500.00

From: [Will Auclair](#)
To: [Mark Shaeffer](#)
Subject: RE: Request for No bid quote for replacement pump
Date: Wednesday, January 20, 2021 7:30:50 AM
Attachments: [image002.png](#)
[image003.png](#)

[CAUTION] This email originated from outside of the organization. Do not follow guidance, click links, or open attachments unless you recognize the sender and know the content is safe.

Mark,

We cannot quote this particular Flygt pump as we are not a Flygt distributor.

Best Regards,
Will Auclair

Address: 632-B Lovejoy Road NW
Fort Walton Beach, FL 32548
Office PH: 850-864-4000
Email: wauclair@gilbertpump.net



A Goforth Williamson Company

*****There are some exciting changes that will enhance the way we service our customers.*****
*****Look for future updates coming soon.*****

From: Mark Shaeffer <Mark.Shaeffer@pcbfl.gov>
Sent: Tuesday, January 19, 2021 9:56 AM
To: Will Auclair <wauclair@gilbertpump.net>
Subject: Request for No bid quote for replacement pump

Will, can you assist me in a procurement issue? In order to purchase a replacement pump for this unit from Flygt, I have to secure quotes from other vendors indicating that they cannot provide a quote for this pump. As this unit is paired with another unit in a duplex station, we have to match it exactly.

Can you send me an email indicating that you cannot provide a quote for this pump and possibly stating the reasons why? I am trying to get this item on the upcoming council agenda and need two other quotes from pump vendors that we use.

Mark Shaeffer, P.E.
Utilities Director
City of Panama City Beach
17007 Panama City Beach Parkway
Panama City Beach, FL 32413

O (850) 233-5100, Ext. 2321

C (850) 832-9327

www.pcbfl.gov



 **AAG SERVICES, INC.**

2340 INDUSTRIAL DR PANAMA CITY, FL 32405

PHONE: 850-763-9386 FAX 850-785-8545

WWW.AAGPUMPS.COM



January 19, 2021


**Mr. Mark Shaeffer, P.E.
City of Panama City Beach
Panama City Beach, Florida**

**RE: Pump Repair LS #109 - Flygt Pump
AAG Project Number: 21654**

Mark,

Per our previous conversations, AAG Services, Inc. is not an authorized FLYGT pump distributor and therefore cannot provide an exact replacement pump. If you have any questions or need further information, please feel free to call or E-Mail.

Best Regards,

A handwritten signature in blue ink, appearing to read "Brian D. Justice".

Brian D. Justice, P.E.
Engineering Services Manager
brian@aagpumps.com

Cc: Keith Gay, AAG Services, Inc.