



## CITY OF PANAMA CITY BEACH

May 17, 2024

### ADDENDUM NO. 1

## PCB24-32 ITB SLUDGE DEWATERING POLYMER

#### Questions:

1. Please provide current pricing and supplier along with a previous bid tabulation.

**A.** Current supplier is CedarChem was a price of \$2.03 per lb. The bid tabulation from FY2023 has been attached for reference.

2. What is the current dose for the polymer?

**A.** The current dosage rate is 0.8%.

3. Will the incumbent, listed in Table A, be required to perform full scale trials as part of the testing for "equals" alternatives?

**A.** Yes, the biosolids characteristics change constantly, therefore, the plant will want updated data to compare against all bid submissions.